

CITY COUNCIL
TUESDAY, FEBRUARY 21, 2017
WORK SESSION ~ FACILITY PLAN UPDATE & PRELIMINARY DESIGN

Mayor Burge called the work session to order at 6:30 p.m.

Present: Mayor Scott Burge, Council President Mark Reed, Councilor Barb Hayden, Councilor Rich Riffle, Councilor Megan Greisen, Councilor Natalie Sanders, City Manager Michael Sykes, Legal Counsel Shelby Rihala, Police Chief Norm Miller, City Recorder Susan Reeves, Treatment Plant Supervisor Kevin Turner, City Engineer Chris Negelspach, and Ben Tolles AmeriCorps RARE Member.

Excused: Councilor Patrick Kessi

City Manager Sykes explained as you may know staff has been working on our Wastewater Master Plan Update and that has led us to identify some immediate improvements that we are going to need to really consider laying the ground work for. He explained tonight is a presentation about some of those improvements and some of the work that we would like to ask the Council for support to move forward on in the Council meeting.

Treatment Plant Supervisor Kevin Turner went over his handout. He explained last year in February staff kicked off the facility plan with the flow testing. He explained staff put some monitoring devices inside some manholes around the City to collect the data and follow that up in the summer with smoke testing to look for illegal connections, which they found some, which lead into Keller's first draft. He explained originally Keller had not included the Urban Growth Boundary, and staff had them go back and look at that. He explained they had all the information reviewed by Carollo Engineering and they had some different ideas. He explained Carollo's flow population numbers were drastically different. Carollo thinks the population of flow will be closer to what Portland State has predicted with their moderate growth. It is on the hand out referenced PSU vs draft. He explained if we go with Carollo to update these figures it is going to push a lot of those improvements beyond the 20 year outlook and save the budget millions of dollars. He explained in the handout he has included their draft 20 year CIP and you can see all the different things. He went over the priority items. He explained with Carollo's proposal they want to model the plant also, which Keller did not do. He explained by doing that it would give us a better look at how the process works. He explained basically this all comes down to Kellers projection of 7.2 million gallons versus the estimate numbers from Carollo which would be closer to 3.9 million gallons per day over those 20 years. He explained their proposal to finish it would be about \$99,000 but it would also include predesign to move us forward towards those priority one improvements.

**Wastewater Facility Plan Update
and Treatment Plant Predesign**

Work Session Handout



Introduction

- The current ***draft*** facility plan identifies an estimated \$43 million in capital improvement projects over the next 20 years.
- Moving forward with Carollo Engineering, Inc. proposed review, update, and predesign will save millions in capital improvements over the next 20 years
- Predesign will layout critical improvements needed to serve the current and short term population and flows.



Current Design

- 1.5 Million Gallons per Day (MGD)
 - With everything working correctly and normal concentration the plant should handle this flow
- Peak Design Flow 3.2 MGD
 - Maximum capacity of current pumps and piping

Draft Facility Plan Projected Population and Flow

| | 2015 Design Flow (MGD) | Projected Unit Flow (gpcd) | Projected Flows [Domestic and Industrial] (MGD) | | | |
|---------------------|------------------------|----------------------------|---|--------|--------|--------|
| Year | 2015 | 2015 | 2020 | 2025 | 2030 | 2035 |
| Population | 6,745 | 6,745 | 9,943 | 10,924 | 12,003 | 13,188 |
| AADF | 0.768 | 114 | 1.176 | 1.777 | 2.166 | 2.390 |
| ADWF | 0.660 | 98 | 1.015 | 1.563 | 1.916 | 2.114 |
| AWWF | 0.860 | 127 | 1.315 | 1.960 | 2.382 | 2.628 |
| MMDWF ₁₀ | 0.855 | 127 | 1.308 | 1.952 | 2.372 | 2.616 |
| MMWWF ₅ | 1.212 | 180 | 1.845 | 2.663 | 3.207 | 3.537 |
| PWkF | 1.397 | 207 | 2.124 | 3.032 | 3.640 | 4.013 |
| PDAF ₅ | 1.850 | 274 | 2.805 | 3.935 | 4.700 | 5.181 |
| PIF ₅ | 2.640 | 391 | 3.995 | 5.510 | 6.549 | 7.218 |

PSU vs. Draft

| | Design Flow (MGD) | Projected Unit Flow (gpcd) | Projected Domestic Flows (MGD) | | | | City Projected Flows (MGD) | |
|---------------------|-------------------|----------------------------|---|-------|-------|-------|-----------------------------------|------------------------------|
| | | | (PSU Moderate Growth Rate Pop. Projections) | | | | (City Estimated Pop. Projections) | |
| Year | 2015 | 2015 | 2020 | 2025 | 2030 | 2035 | 2035 Domestic | 2035 Domestic and Industrial |
| Population | 6,745 | 6,745 | 7,520 | 8,262 | 9,078 | 9,974 | 13,188 | 13,188 |
| AADF | 0.768 | 114 | 0.856 | 0.940 | 1.033 | 1.135 | 1.501 | 2.390 |
| ADWF | 0.660 | 98 | 0.736 | 0.809 | 0.889 | 0.977 | 1.291 | 2.114 |
| AWWF | 0.860 | 128 | 0.959 | 1.053 | 1.157 | 1.271 | 1.681 | 2.628 |
| MMDWF ₁₀ | 0.855 | 127 | 0.954 | 1.048 | 1.151 | 1.265 | 1.672 | 2.616 |
| MMWWF ₅ | 1.212 | 180 | 1.352 | 1.485 | 1.631 | 1.792 | 2.370 | 3.537 |
| PWkF | 1.397 | 207 | 1.558 | 1.711 | 1.880 | 2.066 | 2.732 | 4.013 |
| PDAF ₅ | 1.850 | 274 | 2.063 | 2.266 | 2.490 | 2.736 | 3.617 | 5.181 |
| PIF ₅ | 2.640 | 391 | 2.943 | 3.234 | 3.553 | 3.904 | 5.162 | 7.218 |

Draft Plant Capacity Summary

| Component | Capacity (MGD) | 2015 Cap'y Needed (MGD) | 2035 Cap'y Needed (MGD) | Comments |
|-------------------------|---------------------------|-------------------------|-------------------------|---|
| Influent Screen | 4.1 (PIF ₃) | 2.6 | 7.2 | No redundancy |
| Influent Pumps | 3.5 (PIF ₃) | 2.6 | 7.2 | 3 pumps in service (4 th is redundant) |
| Influent Pipe | 4.0 (PIF ₃) | 2.6 | 7.2 | -- |
| Influent Measurement | 5.7 (PIF ₃) | 2.6 | 7.2 | -- |
| Aeration Basin | 1.9 (MMWWF ₃) | 1.2 | 3.5 | Basin integrity (no redundancy) |
| Aeration Basin Aerators | 1.1 (MMWWF ₃) | 1.2 | 3.5 | One aerator is redundant |
| Secondary Clarifiers | 1.0 (MMWWF ₃) | 1.2 | 3.5 | No Redundancy with Solids Loading |
| RAS Pumps | 2.0 | 1.3 | 2.6 | 2 pumps in service (3 rd is redundant) |
| RAS Pipe | 1.0 | 1.3 | 2.6 | -- |
| WAS Pumps | 0.2 | 0.04 | 0.08 | Open/close valves for redundancy |
| WAS Pipe | 0.2 | 0.04 | 0.08 | -- |
| Tertiary Pump Station | 2.0 (PIF ₃) | 2.6 | 7.2 | Second pump is redundant |
| Tertiary Pipe | 9.2 (PIF ₃) | 2.6 | 7.2 | -- |
| Tertiary Filters | 1.2 (MMWWF ₃) | 1.2 | 3.5 | Second filter is redundant |
| UV Disinfection | 3.1 (PIF ₃) | 2.6 | 7.2 | One module redundant |
| Effluent Measurement | 3.3 (PIF ₃) | 2.6 | 7.2 | -- |
| Effluent Pumps | 3.3 (PIF ₃) | 2.6 | 7.2 | 3 pumps in service (4 th is redundant) |
| Effluent Pipe | 4.0 (PIF ₃) | 2.6 | 7.2 | -- |


20 Year Draft CIP

| ID# | Item | WWTP Flow Trigger | Additional EDUs to Meet Flow Trigger | Total Estimated Cost (2016) | SDC Growth Portion % | Cost | City's Estimated Portion |
|--|--|----------------------------|--------------------------------------|-----------------------------|----------------------|----------------------|--------------------------|
| Priority 1 Improvements | | | | | | | |
| Wastewater Collection System | | | | | | | |
| 1A.1 | New, Relief Trunk Line | -- | -- | \$ 1,720,000 | 30% | \$ 516,000 | \$ 1,204,000 |
| 1A.2 | E Columbia Ave Trunk Line | -- | -- | \$ 1,290,000 | 59% | \$ 761,000 | \$ 529,000 |
| 1A.3 | SE Tyler St and SE Tussing Wy Trunk Line | -- | -- | \$ 630,000 | 49% | \$ 309,000 | \$ 321,000 |
| 1A.4 | SW Em Watts Rd Trunk Line | -- | -- | \$ 270,000 | 35% | \$ 95,000 | \$ 175,000 |
| 1B | NW Smith Road Trunk Line | -- | -- | \$ 160,000 | 6% | \$ 10,000 | \$ 150,000 |
| 1C | Lift Station Improvements | -- | -- | \$ 410,000 | 0% | \$ - | \$ 410,000 |
| Wastewater Treatment | | | | | | | |
| 1a | Interim Biosolids Plan | Beyond Capacity | -- | \$ 2,530,000 | 33% | \$ 843,000 | \$ 1,687,000 |
| 1b | Rehabilitate UV System | -- | -- | \$ 373,000 | 15% | \$ 55,000 | \$ 318,000 |
| 1c.1 | Add 3rd pump to Inter. Pump Station | Beyond Capacity | -- | \$ 35,000 | 70% | \$ 25,000 | \$ 10,000 |
| 1c.2 | Add disks to existing Tertiary Filters | At Capacity | -- | \$ 97,000 | 100% | \$ 97,000 | \$ - |
| 1d | SCADA System | -- | -- | \$ 297,000 | 63% | \$ 188,000 | \$ 109,000 |
| 1e.1 | Aeration for Aeration Basin | Beyond Capacity | -- | \$ 341,000 | 33% | \$ 114,000 | \$ 227,000 |
| 1e.2 | Sec. Clarifier and Sludge Bldg. Exp. | Beyond Capacity | -- | \$ 2,190,000 | 100% | \$ 2,190,000 | \$ - |
| Total Priority 1 Improvements (rounded) | | | | \$ 10,340,000 | | \$ 5,200,000 | \$ 5,140,000 |
| Rate Impact (20 yr, 1.6%) | | | | \$ 18.77 | | | \$ 9.33 |
| Priority 2 Improvements | | | | | | | |
| Wastewater Collection System | | | | | | | |
| 2A | SE 6th St Trunk Line | -- | -- | \$ 610,000 | 100% | \$ 610,000 | \$ - |
| 2B | NE Laurel St and NE 3rd St Trunk Line | -- | -- | \$ 370,000 | 100% | \$ 370,000 | \$ - |
| 2C | Lift Station Improvements | -- | -- | \$ 240,000 | 26% | \$ 62,000 | \$ 178,000 |
| Wastewater Treatment | | | | | | | |
| 2a.1 | New Aeration Basins | 1.9 MGD MMWWF ₃ | 1,530 | \$ 7,750,000 | 54% | \$ 4,173,000 | \$ 3,577,000 |
| 2a.2 | New Aerobic Digester | 1.8 MGD MMWWF ₃ | 1,310 | \$ 2,020,000 | 48% | \$ 966,000 | \$ 1,054,000 |
| 2b.1 | Expand Headworks | 4.1 MGD PIF ₃ | 1,500 | \$ 3,410,000 | 63% | \$ 2,163,000 | \$ 1,247,000 |
| 2b.2 | Upgrade Influent Pumps | 3.5 MGD PIF ₃ | 880 | \$ 928,000 | 63% | \$ 589,000 | \$ 339,000 |
| 2c.1 | Upgrade Effluent Pumps | 3.3 MGD PIF ₃ | 675 | \$ 833,000 | 63% | \$ 528,000 | \$ 305,000 |
| 2c.2 | Increase Effluent Pipe | 4.0 MGD PIF ₃ | 1,400 | \$ 2,100,000 | 63% | \$ 1,332,000 | \$ 768,000 |
| 2d.1 | Upgrade Intermediate Pump Station | 4.0 MGD PIF ₃ | 1,400 | \$ 455,000 | 100% | \$ 455,000 | \$ - |
| 2d.2 | Additional Tertiary Filter Unit | 1.8 MGD MMWWF ₃ | 1,310 | \$ 877,000 | 100% | \$ 877,000 | \$ - |
| 2e | Upgrade UV System | 3.1 MGD PIF ₃ | 480 | \$ 1,117,000 | 63% | \$ 709,000 | \$ 408,000 |
| Total Priority 2 Improvements (rounded) | | | | \$ 20,710,000 | | \$ 12,830,000 | \$ 7,880,000 |


20 Year Draft CIP cont.

| ID# | Item | WWTP Flow Trigger | Additional EDUs to Meet Flow Trigger | Total Estimated Cost (2014) | SDC Growth Factor | City's Estimated Portion |
|--|-------------------------------------|----------------------------|--------------------------------------|-----------------------------|-------------------|-----------------------------------|
| Priority 3 Improvements | | | | | | |
| Wastewater Collection System | | | | | | |
| 3A | SW Old Portland Rd Trunk Line | -- | -- | \$ 280,000 | 100% | \$ 280,000 \$ - |
| 3B | SE Tussing Wy Trunk Line | -- | -- | \$ 50,000 | 40% | \$ 20,000 \$ 30,000 |
| Wastewater Treatment | | | | | | |
| 3a.1 | Additional Aeration Basin | 2.6 MGD MMWWF ₅ | 3,090 | \$ 3,220,000 | 100% | \$ 3,220,000 \$ - |
| 3a.2 | Additional Secondary Clarifier | 3.4 MGD MMWWF ₅ | 4,870 | \$ 1,320,000 | 100% | \$ 1,320,000 \$ - |
| 3b.1 | Additional Aerobic Digester | 2.3 MGD MMWWF ₅ | 2,420 | \$ 1,830,000 | 100% | \$ 1,830,000 \$ - |
| 3b.2 | Additional Screw Presses | 2.3 MGD MMWWF ₅ | 2,420 | \$ 1,684,000 | 100% | \$ 1,684,000 \$ - |
| 3c | Plant Water System | -- | -- | \$ 208,000 | 63% | \$ 132,000 \$ 76,000 |
| Total Priority 3 Improvements (rounded) | | | | \$ 8,590,000 | | \$ 8,490,000 \$ 110,000 |
| Priority 4 Improvements | | | | | | |
| Wastewater Collection System | | | | | | |
| 4A | P.LS 1, Force Main and Gravity Line | -- | -- | \$ 660,000 | 100% | \$ 660,000 \$ - |
| 4B | P.LS 2, Force Main and Gravity Line | -- | -- | \$ 1,160,000 | 100% | \$ 1,160,000 \$ - |
| 4C | P.LS 3 and Force Main | -- | -- | \$ 750,000 | 100% | \$ 750,000 \$ - |
| 4D | P.LS 4, Force Main and Gravity Line | -- | -- | \$ 1,210,000 | 100% | \$ 1,210,000 \$ - |
| Total Priority 4 Improvements (rounded) | | | | \$ 3,780,000 | | \$ 3,780,000 \$ - |
| TOTAL WASTEWATER IMPROVEMENTS COSTS (rounded) | | | | \$ 43,420,000 | | \$30,300,000 \$ 13,130,000 |

Current Layout



Draft Improvements



Update Scope

City of Scappoose Wastewater Facilities Plan Update and Treatment Plant Predesign

Carollo Engineers, Inc. will provide the following services related to the city's wastewater treatment plant with the goals of

- 1) providing the city with an amended planning document that identifies and details necessary WWTP capital improvements over the 20-year planning period,
- 2) providing the City with a state-approvable facilities plan that satisfies all requirements for the City applying for State Revolving Fund financing for near term improvements, and
- 3) providing a predesign of the capital improvements that the City needs to complete in the near-term (first five years).

Project Schedule: The scope of work The Final Facility Plan Update and Treatment Plant Predesign is scheduled to be completed within 4 months following the Notice to Proceed.

Project Fee: The total fee for the scope of work presented is a lump sum cost not to exceed \$99,466.

Recent Flows

- November 2016
 - Max daily flow 2.632 MGD, 25th
 - Peak instantaneous flow 3.2 MGD (2222 gallons per minute)
- January 2017
 - Average daily flow – 1.168 MG
 - Max daily flow 2.191 MG
 - Peak instantaneous flow – 2.8 MG (1944 gallons per minute)
- February 2017 – past two weeks
 - Average daily flow – 1.478 MG
 - Max daily flow – 1.950 MG
 - Peak instantaneous flow – 2.7 MG (1875 gallons per minute)

Treatment Plant Supervisor Kevin Turner explained staff wanted to bring this to Council in a work session in case there were some questions.

City Manager Sykes stated he thinks it is important to note that the Wastewater Master Plan is dated 1998, and basically we have to update that to get any grants or loans from DEQ. He explained the amount proposed by Keller just didn't seem like a reasonable number so staff decided that it was really important to get somebody in here who has a good reputation in the industry and so they ended up picking Carollo.

Councilor Hayden stated there is such a difference in the population estimates going forward, it is incredible.

Mayor Burge stated he thinks part of this is they are supposed to use the PSU numbers.


City Manager Sykes explained it is important to make sure we have our System Development Charges inline so when new development comes in we can charge proportionally and can capitalize on that opportunity.

Council thanked Kevin.

Adjournment ~ Mayor Burge adjourned the Work Session at 6:55 p.m.



Scott Burge, Mayor

Attest: 

Susan M. Reeves, MMC, City Recorder