

SCADA RFQ Q & A's

Q: What brand of PLC's do you have?

A: The City has Allen Bradley at the Miller Road Treatment Plant and Control Microsystems/Schneider at the Keys Road Treatment Plant

Q: The RFQ requests three hard copies (1 original), does that mean the City wants one original plus three hard copies?

A: The City is requesting three hard copies total, with one original

Q: What is the total estimated value of the two year contract?

A: The Water Department has budgeted \$125,000 for upgrades to the water control's system. The Wastewater Department has not budgeted to move forward with upgrades at this time

Q: What is the status of Wonderware / is the City committed to it or can other programs be proposed?

A: The City is open to suggestions

Q: Is this project to identify an Integrator of Record?

A: No