



SCAPPOOSE
Oregon

To: RFP 2022-04 Prospective Proposers
From: Huell Whitehaus, Assistant to Public Works Director
Date: July 20, 2022
RE: City's responses to pre-proposal questions (RFP 2022-04)

Below is a list of questions received to-date pertaining the City of Scappoose's solicitation RFP 2022-04.

- 1. Item 4.4 – Can the two-page maximum limit be utilized in one 11 x 17 page?** *Yes.*
- 2. Item 4.5 – Are you looking for three projects exclusively, or can we include more than three (keeping within the 6-page max)?** *Proposers are certainly welcome to include more examples as long as it remains the page limit.*
- 3. Has the firm capacity of the existing wet well been tested?** *No, just estimated. The information is included in the 2021 Collection System Facilities Planning Study.*
- 4. Are as-builts available for the existing facility?** *Yes, however, only in hard copy.*
- 5. Has the down stream flow capacity been increase per the master plan?** *Yes, per the Columbia Avenue sewer project.*
- 6. How was this project funded?** *The City is a recipient of grant funds for this project from the American Rescue Plan Act via Oregon House Bill 5006.*
- 7. Will a digital plan room be utilized? If yes, would the City set up the plan room?** *Yes, a digital plan room will be utilized and will be set up by the City once the plans and specifications are ready to be advertised for competitive bidding for construction.*
- 8. Who will do the PLC design for the new pump station?** *The City's SCADA Integrator of Record.*
- 9. Are there any geotechnical reports available from nearby projects?** *The City has geotechnical reports from 2009 and 2018 for Veterans and Chief Concomly Parks, respectively, but no reports specific to pump station site.*